



THERMOSEAL, LLC
P.O. Box 32
New Canaan, CT 06840
(800) 853-1577

THERMOSEAL ONE

CSI Section:

07 21 00 Thermal Insulation

1.0 RECOGNITION

Thermoseal ONE recognized in this report has been evaluated for use as a spray-applied polyurethane foam plastic (SPF) insulation and is used as a nonstructural thermal insulating material in Type V construction under the IBC and dwellings under the IRC. The surface-burning characteristics, physical properties, thermal resistance and water vapor transmission properties of Thermoseal ONE comply with the intent of the provisions of the following codes and regulations:

- 2018, 2015 and 2012 International Building Code® (IBC)
- 2018, 2015 and 2012 International Residential Code® (IRC)
- 2018, 2015 and 2012 International Energy Conservation Code® (IECC)
- 2017 Florida Building Code, Building (FBC, Building) – Supplement attached
- 2017 Florida Building Code, Residential (FBC, Residential) – Supplement attached
- 2017 Florida Building Code, Energy Conservation (FBC, Energy Conservation) – Supplement attached

2.0 LIMITATIONS

Use of Thermoseal ONE recognized in this report is subject to the following limitations:

2.1 The insulation and coating products shall be installed in accordance with the manufacturer's published installation instructions, this evaluation report and the applicable code. Where conflicts occur, the most restrictive requirements shall govern.

2.2 Thermoseal ONE closed-cell spray-applied polyurethane foam insulation shall be installed by contractors certified by Thermoseal Inc.

2.3 Use of Thermoseal ONE closed-cell spray-applied polyurethane foam insulation is used in areas where the likelihood of termite infestation is “very heavy,” it shall be installed in accordance with IBC Section 2603.8 (2012 IBC Section 2603.9) or IRC Section R318.4, as applicable.

2.4 Jobsite labeling, and certification of the insulation shall comply with the 2018 and 2015 IRC Sections N1101.10 and N1101.10.1.1, 2012 IRC Sections N1101.12 and N1101.12.1, IRC Sections N1101.4 and N1101.4.1 and IECC Sections C303.1.1 and C303.1.2, as applicable.

2.5 Where applicable, Thermoseal ONE closed-cell spray-applied polyurethane foam insulation shall be installed with a vapor retarder in accordance with the applicable code.

2.6 Except as indicated in Section 3.3.3.2 of this report or by the applicable code, the insulations shall be separated from the interior of the building by a code approved thermal barrier.

2.7 During installation the insulations and the surfaces to which they are applied shall be protected from exposure to weather.

2.8 The spray-foam insulation recognized in this report is produced in Norwalk, Connecticut.

3.0 PRODUCT USE

3.1 General: Thermoseal ONE is a spray-applied polyurethane foam plastic (SPF) insulation and is used as a nonstructural thermal insulating material in Type V construction under the IBC and dwellings under the IRC. The insulation complies with IBC Section 2603, Section R316 and IECC Sections C303, C402, R303; and R402.

3.2 Design:

3.2.1 Surface Burning Characteristics: The Thermoseal ONE closed-cell spray-applied polyurethane foam insulation, at a maximum thickness of 4 inches (102 mm) and a nominal density of 2.45 pcf (32.0 kg/m³), has a flame spread index of 25 or less and a smoke-developed index of 450 or less when tested in accordance with ASTM E84. Thicknesses are not limited for ceiling cavities and wall cavities when covered by a code complying prescriptive thermal barrier, such as minimum ½-inch thick (12.7 mm) gypsum board.

3.2.1 Thermal Resistance: For uses in accordance with the IECC or other codes, Thermoseal ONE closed-cell spray-applied polyurethane foam insulation has a thermal resistance, R-value, at a mean temperature of 75°F (24°C) as shown in Table 1 of this report.

The product described in this Uniform Evaluation Service (UES) Report has been evaluated as an alternative material, design or method of construction in order to satisfy and comply with the intent of the provision of the code, as noted in this report, and for at least equivalence to that prescribed in the code in quality, strength, effectiveness, fire resistance, durability and safety, as applicable, in accordance with IBC Section 104.11. This document shall only be reproduced in its entirety.





Table 1 – Thermal Resistance (R-Values)¹

Thickness (inch)	R-Value (°F•ft ² •hr/Btu)
1.0	7.0
3.5	25
4.0	28
5.5	39
7.5	53
9.5	67
11.5	81
14	99

SI: 1 inch = 25.4 mm; 1 °F•ft²•hr/Btu = 0.176 °K•m²•hr/W
¹R-values are calculated based on tested k-factors at 1- and 3.5-inch thicknesses.

3.2.2 Vapor Retarder: Thermoseal ONE closed-cell spray-applied polyurethane foam insulation has a vapor permeance of 1.2 perm, when applied at a minimum thickness of 1 inch (25.4 mm) and qualifies as a Class III vapor retarder as defined in IRC Section R202.

3.3 Installation:

3.3.1 Installation General: Thermoseal ONE closed-cell spray-applied polyurethane foam insulation shall be installed in accordance with the manufacturer's published installation instructions and this report. A copy of these instructions and this evaluation report shall be available on the jobsite at all times during installation. Where conflicts occur, the more restrictive shall govern.

3.3.2 Application: Thermoseal ONE closed-cell spray-applied polyurethane foam insulation shall be applied using spray equipment specified by Thermoseal Inc.

3.3.3 Thermal Barrier:

3.3.3.1 Application with a Prescriptive Thermal Barrier: Thermoseal ONE closed-cell spray-applied polyurethane foam insulation must be separated from the interior of the building by an approved thermal barrier of 1/2-inch-thick (12.7 mm) gypsum wallboard or an equivalent 15-minute thermal barrier complying with and installed in accordance with the applicable code.

3.3.3.2 Application with an Alternative Thermal Barrier Assembly: Thermoseal ONE closed-cell spray-applied polyurethane foam insulation when used with DC315 intumescent coating as an alternative thermal barrier assembly as described in this section, may be spray-applied to the interior facing of walls and may be left exposed as an interior finish without a prescribed 15-minute prescriptive thermal barrier. The thickness of the foam plastic applied to the underside of the ceiling or other horizontal spaces must not exceed 9.5 inches (241.3 mm). The thickness of the foam plastic applied to vertical wall surfaces must not exceed 5.5 inches (139.7 mm). The foam plastic must be covered on all surfaces with DC315 Fireproof Paint at a minimum wet film thickness of 20 mils (13 mils dry film thickness), at a rate of

1.3 gallons (4.7 L) per 100 square feet (9.2 m²). The coating must be applied over the Thermoseal ONE closed-cell spray-applied polyurethane foam insulation in accordance with the coating manufacturer's instructions and this report. Surfaces to be coated must be dry, clean and free of dirt, loose debris, and other substances that could interfere with adhesion of the coating.

3.3.4 Attics and Crawl Spaces:

3.3.4.1 Application with a Prescriptive Ignition Barrier:

When Thermoseal ONE closed-cell spray-applied polyurethane foam insulation is installed within attics or crawl spaces where entry is made only for service of utilities, an ignition barrier shall be installed in accordance with IBC Section 2603.4.1.6 and IRC Sections R316.5.3 and R316.5.4, as applicable. The ignition barrier must be consistent with the requirements for the type of construction required by the applicable code and must be installed in a manner so that the foam plastic insulation is not exposed.

Thermoseal ONE closed-cell spray-applied polyurethane foam insulation, as described in this section, may be installed in unvented attics in accordance with IBC Section 2603.4 or IRC Section R806.4, as applicable. The attic or crawl space area must be separated from the interior of the building by an approved 15-minute thermal barrier as described in Section 3.3.3 of this report.

3.3.4.2 Application with an Alternative Ignition Barrier Assembly:

Where the spray-applied insulation is installed in accordance with the following conditions, the prescriptive ignition barrier as required in Section 3.3.4.1 is not required:

- a) Entry to the attic or crawl space is to service utilities, and no storage is permitted.
- b) There are no interconnected attic or crawl space areas.
- c) Air in the attic or crawl space is not circulated to other parts of the building.
- d) Attic ventilation is provided when required by the 2018 IBC Section 1202.2, 2015 and 2012 IBC Section 1203.2 or IRC Section R806, except when air impermeable insulation is permitted in unvented attics in accordance with Section 1202.3 of the 2018 IBC, Section 1203.3 of the 2015 IBC or the IRC Section R806.5, as applicable. Under-floor (crawl space) ventilation is provided when required by IBC Section 1203.3 or IRC Section R408.1, as applicable.
- e) Combustion air is provided in accordance with International Mechanical Code® Section 701.
- f) DC315 Intumescent coating is applied as required in Section 3.3.4.2.1.

3.3.4.2.1 Application with DC315 Intumescent Coating:

Thermoseal ONE closed-cell spray-applied polyurethane foam insulation may be spray-applied to the underside of roof



rafters; and in crawl spaces, Thermoseal TS ONE closed-cell spray-applied polyurethane foam insulation may be applied to the underside of floors as described in this section. The thickness of the foam plastic applied to the underside of the top space must not exceed 9 1/2 inches (241.3 mm). The thickness of the foam plastic applied to vertical surfaces must not exceed 5 1/2 inches (139.7 mm). All foam plastic surfaces must be covered with DC315 Fireproof Paint described in Section 4.2 of this report. The intumescent coating must be applied over the Thermoseal ONE closed-cell spray-applied polyurethane foam insulation in accordance with the manufacturer's instructions and this report. The foam plastic insulation must be covered with 20 wet mils (13 dry mils) of DC315 Fireproof Paint coating applied in a single coat at a rate of 1.3 gallons (4.7 L) per 100 square feet (9.2 m²). Surfaces to be coated must be dry, clean and free of dirt, loose debris, and other substances that could interfere with adhesion of the coating. The attic and crawl space area must be separated from the interior of the building by an approved 15-minute thermal barrier as described in Section 3.3.3.

3.3.4.3 Use on Attic Floors: Thermoseal TS ONE closed-cell spray-applied polyurethane foam insulation may be installed at a maximum thickness of 9 1/2 inches (241.3 mm) between joists of the attic floor. The insulation shall have an ignition barrier applied on the surface meeting the requirements of Section 3.3.4.1 or 3.3.4.2 and shall be separated from the area beneath the attic by an approved thermal barrier.


4.0 PRODUCT DESCRIPTION

4.1 Thermoseal ONE: Thermoseal ONE closed-cell spray-applied polyurethane foam insulation is a medium-density spray-applied, closed cell polyurethane foam plastic insulation having a nominal density of 2.45 pcf (39.2 kg/m³).

4.2 DC315 Intumescent Coating: DC315 Fireproof Paint, recognized in ER-499, is manufactured by International Fireproof Technology, Inc. and is a water-based coating supplied in 5-gallon (19 L) pails and 55- gallon (208 L) drums. The coating material has a shelf life of 24 months when stored in factory-sealed containers at temperatures between 50°F (10°C) and 90°F (32°C).

5.0 IDENTIFICATION

Thermoseal ONE is identified by the Thermoseal name and trademark, product name the lot number; the flame spread and smoke developed indices; mixing instructions; the shelf life; the expiration date; and evaluation report number (ER-602). The identification includes the IAPMO Uniform Evaluation Service Mark of Conformity. Either Mark of Conformity may be used as shown below:



or
IAPMO UES ER-602

6.0 SUBSTANTIATING DATA

Data and test reports submitted are from laboratories in compliance with ISO/IEC 17025 and in accordance with the ICC-ES Acceptance Criteria for Spray-applied Foam Plastic Insulation, (AC377), Approved April 2016.

7.0 STATEMENT OF RECOGNITION

This evaluation report describes the results of research carried out by IAPMO Uniform Evaluation Service on Thermoseal ONE to assess conformance to the codes shown in Section 1.0 of this report and serves as documentation of the product certification. Products are manufactured at the location noted in Section 2.8 of this report under a quality control program with periodic inspection under the supervision of IAPMO UES.

Brian Gerber

Brian Gerber, P.E., S.E.
Vice President, Technical Operations
Uniform Evaluation Service

Richard Beck

Richard Beck, PE, CBO, MCP
Vice President, Uniform Evaluation Service

Russ Chaney

GP Russ Chaney
CEO, The IAPMO Group

For additional information about this evaluation report please visit www.uniform-es.org or email us at info@uniform-es.org



FLORIDA SUPPLEMENT

THERMOSEAL, LLC
P.O. Box 32
New Canaan, CT 06840
(800) 853-1577

Thermoseal ONE Closed Cell Spray-Applied Foam Plastic Insulations

CSI Section:

07 21 00 Thermal Insulation

1.0 RECOGNITION

The Thermoseal ONE closed cell spray-applied foam plastic insulations as evaluated and represented in IAPMO UES Evaluation Report ER-602 and with changes as noted in this supplement is a satisfactory alternative for use in buildings built under the following codes (and regulations):

- 2017 Florida Building Code, Building, (FBC, Building)
- 2017 Florida Building Code, Residential (FBC, Residential)
- 2017 Florida Building Code, Energy Conservation (FBC, Energy Conservation)

2.0 LIMITATIONS

Use of Thermoseal ONE closed cell spray-applied foam plastic insulations recognized in this report is subject to the following limitations:

2.1 The clearance between the foam insulation installed above grade and exposed earth shall be in accordance with Section 2603.8 of the FBC, Building or Section R318.8 of the FBC, Residential.

2.2 Verification shall be provided that a quality assurance agency audits the manufacturers quality assurance program and audits the production quality of products in accordance with Section (5)(d) of Florida Rule 61G20-3.008. The quality assurance agency shall be approved by the Commission (or the building official when the report holder does not possess an approval by the Commission).

For additional information about this evaluation report please visit www.uniform-es.org or email us at info@uniform-es.org